



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title		Edition
A17.1 EEC #5		2007
Section number and title		Page
8.6.11.1		298
Proponent	Title	
Jeff Cooper	Elevator Systems Specialist	
Address		Phone
770 Ahlers Drive, West Lafayette, In.		765-496-7372
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>8.6.11.1 Firefighters' Emergency Operation. All elevators provided with firefighters' emergency operation shall be subjected monthly to Phase I recall by use of the key switch, and a minimum of one-floor operation on Phase II, except in jurisdictions enforcing the NBCC. Deficiencies shall be corrected. A record of findings shall be available to elevator personnel and the authority having jurisdiction. <u>Building Owners or their representatives who perform fire service testing shall meet the definition of emergency personnel per Section 1.3.</u></p>		
REASON		
<p>This practice is already being followed but needed additional clarification. No additional costs or savings should be realized.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		